




## Liste codes erreurs



| <b>CODES ERREUR</b> | <b>CODES ERREUR (Voyants)</b> | <b>DESCRIPTION</b>          | <b>VÉRIFICATION</b>         |
|---------------------|-------------------------------|-----------------------------|-----------------------------|
| <b>E3</b>           | <b>3H et 6H</b>               | Défaut sonde de température | Sonde de température ouvert |
| <b>E4</b>           | <b>3H et 6H</b>               | Défaut sonde de température | Sonde de température coupé  |

| <b>VALEURS SONDÉS TEMPERATURES</b> |               |               |               |               |               |               |               |               |               |
|------------------------------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|
| <b>T (°C)</b>                      | <b>R (kΩ)</b> | <b>T (°C)</b> | <b>R (kΩ)</b> | <b>T (°C)</b> | <b>R (kΩ)</b> | <b>T (°C)</b> | <b>R (kΩ)</b> | <b>T (°C)</b> | <b>R (kΩ)</b> |
| 10                                 | 9.6774        | 30            | 3.8990        | 50            | 1.7437        | 70            | 0.8474        | 90            | 0.4432        |
| 15                                 | 7.6313        | 35            | 3.1613        | 55            | 1.4453        | 75            | 0.7158        | 95            | 0.3812        |
| 20                                 | 6.0571        | 40            | 2.5782        | 60            | 1.2040        | 80            | 0.6071        | 100           | 0.3289        |
| 25                                 | 4.8385        | 45            | 2.1146        | 65            | 1.0078        | 85            | 0.5171        |               |               |

*La solution assistance*



*La solution assistance*